




**DELHI JAL BOARD: GNCTD  
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref. No. D.J.B/DTQC/Wzd/2025-26/Paid-237-238		
Location /Address of Sample	Remal Public School, Block A-2, Sector-3, Rohini, Delhi-110085		
Letter Reference No.	RPS/25-26/203	Ref. Letter Date	20.02.2026
Challan No.	272	Challan Date	20.02.2026
Sample Collection date	23.02.2026	Analysis start date	23.02.2026
Any other Information	--	Analysis end date	26.02.2026
		Reporting date	27.02.2026

**TEST RESULTS**

S.No	Parameters	Unit	As per the IS 10500		Inlet (from Storage tank)	Outlet ( RO)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	3.2	1.8
4	pH Value at 27 °C	--	6.5-8.5	No relaxation	7.44	7.12
5	Electrical Conductivity	µS/cm	-	-	280	122
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	182	80
7	Total Alkalinity as CaCO <sub>3</sub>	mg/L	200(Max)	600(Max)	112	64
8	Total Hardness as CaCO <sub>3</sub>	mg/L	200(Max)	600(Max)	120	80
9	Calcium as Ca	mg/L	75(Max)	200(Max)	32	22.4
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	9.6	5.8
11	Iron as Fe	mg/L	1.0(Max)	No relaxation	0.08	0.04
12	Chloride as Cl	mg/L	250(Max)	1000(Max)	22	14
13	Fluoride as F	mg/L	1.0(Max)	1.5(Max)	0.5	0.3
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate as NO <sub>3</sub>	mg/L	45(Max)	No relaxation	10.3	2.9
16	Sulphate as SO <sub>4</sub>	mg/L	200(Max)	400(Max)	68	58
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	0.6	BDL
18	Coliform Count 37°C (MPN)	/100 mL	Absent	No relaxation	0	0

\*BDL=Below Detection Limit

.....End of Report.....

**Remarks: Samples conform specification for the tested parameters and can be considered for drinking purpose.**

Tested by  
Lab.Tech.


Verified for Chemical parameters  
Asstt.Chemist

Verified for MPN  
Bacteriologist

Authorized by  
Chemist

**ACWA(WZD)**

**Asstt. Chief Water Analyst  
D.J.B. (Govt. of N.C.T. of Delhi)  
Water Works, Wazirabad**



**MUNICIPAL CORPORATION**  
**(Office of Dy. Health Officer: Rohini Zone)**  
**Public Health Department**  
**Sector 5 Rohini Delhi -110085**  
**Email: [dhoroheinizone15@gmail.com](mailto:dhoroheinizone15@gmail.com) Tel: 011-27052106**

No.-DHO/RZ/2026/ 26

Date : 13.04.2022

**SCHOOL HEALTH CERTIFICATE**

It is certified that an inspection team headed by area Public health Inspector from Public Health department Rohini Zone inspected **REMAL PUBLIC SENIOR SCHOOL** Situated at **BLOCK-A, POCKET-2, SECTOR-3 Rohini, Delhi-85** on **09.04.2026** and found that the **REMAL PUBLIC SENIOR SEC.** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.

Dy. Health Officer  
Rohini Zone



Dy. Deputy  
Municipal Corporation of Delhi  
Rohini Zone

**Manager**  
**REMAL PUBLIC SENIOR SEC,**  
**BLOCK-A, POCKET-2, SECTOR-3**  
**New Delhi-110085.**